



Bruhat Bengaluru Mahanagara Palike

Medical officer of Health
Kengeri sub division, Bangalore

No.MOH/KEN/PR/01 /2025-2026

Date: 21-05-2025

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Dr. Arun Kumar- MEDICAL OFFICER OF HEALTH and Ramesha D M Sr.H.I from BBMP HEALTH DEPARTMENT inspected the VISHWA VENKATESHWARA INTERNATIONAL SCHOOL at Survey no 72, Tirumala Garden, Kodipalya, Kengeri, Bangalore-560060. on 21/05/2025 and the basis of water test report bearing no PHI/WATER/BAC/209/2025-26 Date:17/05/2025 (PHED LAB) certified that THE VISHWA VENKATESHWARA INTERNATIONAL SCHOOL has safe drinking water facilities for the students and members of staff of the institutions School is also maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T.Government.

This certificate valid till 31-03-2026.

*Content of the seal Translated
from Kannada to English.*

*" Medical Officer"
Kengeri Division, Rajarajeshwari Nagar
Bruhat Bangalore Mahanagara
Palike*

Dr. Arun Kumar

[Signature]
Medical Officer of Health
Kengeri Sub division
Rajarajeshwari Nagar Zone
Bruhat Bangalore mahanagara palike

To
VISHWA VENKATESHWARA INTERNATIONAL SCHOOL
Survey no 72,
Tirumala Garden,
Kodipalya, Kengeri,
Bangalore-560060

XEROX COPY ATTESTED BY ME

[Signature]

RAVI, B.A., LL.B.,
ADVOCATE & NOTARY
No. 2663/J, 6th 'B' Main, RPC Layout
Vijaynagar, Bangalore-560 040



- 6 JUN 2025



Bruhat Bengaluru Mahanagara Palike

Medical officer of Health
Kengeri sub division, Bangalore

No.MOH/KEN/PR/01 /2025-2026

Date: 21-05-2025

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Dr. Arun Kumar- MEDICAL OFFICER OF HEALTH** and **Ramesha D M Sr.H.I** from **BBMP HEALTH DEPARTMENT** inspected the **VISHWA VENKATESHWARA INTERNATIONAL SCHOOL** at Survey no **72, Tirumala Garden, Kodipalya, Kengeri, Bangalore-560060.** on 21/05/2025 and the basis of water test report bearing no **PHI/WATER/BAC/209/2025-26** Date:17/05/2025 (PHED LAB) certified that **THE VISHWA VENKATESHWARA INTERNATIONAL. SCHOOL** has safe drinking water facilities for the students and members of staff of the institutions School is also maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T.Government.

This certificate valid till 31-03-2026.

Dr. Arun Kumar

Medical officer of Health

Kengeri Sub division

Rajarajeshwari nagar zone

Bruhat Bangalore mahanagara palike

To

VISHWA VENKATESHWARA INTERNATIONAL SCHOOL

Survey no 72,

Tirumala Garden,

Kodipalya, Kengeri,

Bangalore-560060

Dated: 17/05/2025

Report of Bacteriological analysis of Water/Effluent sample

Sample No.	Source & Particulars of Water Sample	Opinion				N.S.P.P & FC.
		M.P.N Count	Plate Count	D.C Test	S.P.P	
634	R.O. water	Nic	-	-	SPP	-
<p><i>Adminstrator Vishwa Venkateswara Inter National School Sy No 72, Thirumala Garden Kodipalya (Near Sridas Audda) Kengeri Bangalore - 60</i></p> <p>Note: M.P.N Count: Most probable number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coli found</p>						

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru (PTO)

- Advice:
1. Sample.....
Need effective chlorination before use
 2. Sample.....
Need to avoid possible source of fecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More